

# TOWN OF BABYLON FIRE MARSHAL FIRE DETECTION SYSTEM INSPECTION REPORT

**OFFICE USE ONLY**

<input type="checkbox"/> PASSED	DATE _____
<input type="checkbox"/> FAILED	_____



BUSINESS NAME: _____	
ADDRESS: _____	
FIRE DEPARTMENT: _____	DATE OF INSPECTION: _____



INSPECTION COMPANY NAME: _____		LICENSE NUMBER: _____	
ADDRESS: _____		PHONE NUMBER: _____	
TYPE OF ALARM SYSTEM: _____	CHECK FOR NEW SYSTEM <input type="checkbox"/>	TYPE OF INITIATING CIRCUIT: _____	

**WARNING: FIRE DEPARTMENT SHALL BE NOTIFIED PRIOR TO TESTING ALARM SYSTEM!**  
ATTACH A SEPARATE SHEET FOR ANY DEFICIENCIES AND/OR RECOMMENDED IMPROVEMENTS.

1	GENERAL	Y E S	N O	N/A
a	Is the building occupied?			
b	Is occupancy the same as the previous inspection?			
c	Are all systems the same as previous inspection?			
d	Is the building completely protected?			
e	Are there any new additions or building changes?			
f	Have occupants reviewed the system's operation?			
2	PANEL AND WIRING	Y E S	N O	N/A
a	Are all indicating lights working properly?			
b	Were all supervisory circuits tested and working?			
c	Were all parts of power supply tested and working?			
d	Are all wire termination points secure?			
e	Do all remote annunciators work properly?			
f	Is there any physical damage to exposed wiring?			
3	SMOKE DETECTORS	Y E S	N O	N/A
a	Were the detectors cleaned?			
b	Was each detector tested satisfactorily?			
4	THERMAL DETECTORS	Y E S	N O	N/A
a	Are any detectors covered with paint or debris?			
b	Were at least 20% of the detectors tested?			
5	MANUAL STATIONS	Y E S	N O	N/A
a	Was each station tested for mechanical damage?			
b	Was each station tested?			
c	Are all stations in clear view of occupants?			
6	SPECIAL DETECTING DEVICES	Y E S	N O	N/A
a	Are there any special detecting devices?			
b	Are they maintained to manufacturer specifications?			
c	Were they tested to manufacturer specifications?			

7	SOUNDING DEVICES	Y E S	N O	N/A
a	Were all devices inspected for physical damage?			
b	Were all devices satisfactorily tested?			
c	Are all exterior bells free of growth and debris?			
d	Are all exterior weather enclosures free of rust?			
e	Is the word "FIRE" clearly written on enclosures?			
f	Were all strobe lights satisfactorily tested?			
g	Can sounding devices be heard throughout facility?			
8	VOICE EVACUATION	Y E S	N O	N/A
a	Were all speakers/horns inspected for damage?			
b	Were all speakers tested for an audio signal?			
c	Can voice announcements be heard in all areas?			
d	Were all remote microphones tested satisfactorily?			
e	Was the automatic evacuation signal tested?			
f	Is the automatic signal delay less than 90 seconds?			
g	Is manned location free of combustible material?			
h	Did you witness a voice announcement drill/test?			
9	FIRE PROTECTION SYSTEMS	Y E S	N O	N/A
a	Are fixed extinguishing systems connected to alarm?			
b	Were automatic door releases tested satisfactorily?			
c	Were all automatic fan shut down circuits tested?			
d	Were all water-flow switches tested satisfactorily?			
e	Were all tamper switches tested satisfactorily?			
10	CENTRAL STATION MONITORING	Y E S	N O	N/A
a	Is line seizure operating properly?			
b	Were all channels tested satisfactorily?			
c	Does the 24hr auto-test signal operate properly?			
d	Were alarm circuits tested satisfactorily?			

(PRINT)  
INSPECTOR NAME: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_

*I CERTIFY THAT THIS INSPECTION HAS BEEN PROPERLY CONDUCTED AND ALL OF THE ABOVE STATEMENTS ARE TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.*